

Draft 7/28/00

Prioritized List of FCRPS Operations Which May Be Used During a NW or SW System Reliability Event

1. Regional plea for energy conservation
2. Voluntary load curtailment of industrial users
3. Rescheduling of unit outages
4. Increase Willamette Projects' generation
5. Purchase all available energy
6. Maximize Treaty/Non Treaty water releases
7. GCL - draft at 1.5 ft/day (or until restricted by JDA cutplane)
8. Banks Lake - operate PGs / sag on Banks Lake to elevation 1565 ft.
9. ALF - operate at full power
10. JDA - reduce daytime spill to zero
11. TDA - reduce spill to 30%
12. BON - reduce daytime spill to 50 kcfs
13. BON - operate outside of 1% operating efficiency
14. MCN - operate outside 1% operating efficiency at 50% overload (approx. 72 Mws)
15. HGH - operate all available units (daily shaping as necessary)
16. MCN - operate outside 1% operating efficiency at 50% overload (approx. 81 Mws)
17. *JDA - reduce spill to zero (nighttime)
18. *TDA - reduce spill to zero
19. *BON - reduce spill to zero
20. ♦JDA - increase operating range to 265 ft. to 262.5 ft.
21. ♦Snake River Projects - go to zero nighttime flow
22. ♦GCL - increase to 2 ft/day draft
23. ♦DWR - increase discharge to 21 kcfs
24. ♦LWG - utilize full operating pool
25. ♦LIB - operate all available units (daily shaping as necessary)
26. ♦JDA - increase operating pool range to a low of 260 ft.
27. ♦MCN - pull fish screens

The above list has been coordinated with the Corps' RCC and BOR. RCC requests additional policy coordination the operations extend beyond action item number 16.

- Items 17-19 may be utilized for up to six hours at a time. Judi Johansen will coordinate with the General Strock if additional hours are required.
- Items 20-27 will required additional coordination between Judi Johansen and General Strock before being implimented.