

**Prioritized List of FCRPS Operations Which May Be Used
During a NW or SW System Reliability Event
Revised as of 8/3/00 TMT meeting**

1. Regional plea for energy conservation
2. Voluntary load curtailment of industrial users
3. Rescheduling of unit outages
4. Increase Willamette Projects' generation
5. Purchase all available energy
6. Maximize Treaty/Non Treaty water releases
7. JDA – increase operating range to 265 ft. to 262.5 ft.
8. ψ GCL – draft at 1.5 ft/day (or until restricted by JDA cutplane)
9. LWG – utilize full operating pool
10. ALF – operate at full power to elevation 2062 ft. mindful of ramp rates.
11. TDA – reduce spill to 30%
12. BON – reduce daytime spill to 50 kcfs
13. BON – operate outside of 1% operating efficiency
14. JDA – reduce daytime spill to zero (JDA is expected to be at zero 7/31-8/3)
15. MCN – operate outside 1% operating efficiency at 50% overload (approx. 72 Mws)
16. TDA – reduce spill to 20%
17. *JDA – reduce spill to zero (nighttime)
18. *TDA – reduce spill to zero
19. *IHR – reduce spill to zero
20. *BON – reduce spill to zero
21. MCN - operate outside 1% operating efficiency at 100% overload (approx. 81 Mws)
22. ψ Banks Lake – operate PGs / sag on Banks Lake to elevation 1565 ft.
23. Ω HGH – operate all available units (bring up to 3 units until further notice)
24. \blacklozenge ψ GCL – increase to 2 ft/day draft
25. \blacklozenge Snake River Projects – go to zero nighttime flow (lower Snake projects may go above MOP)
26. \blacklozenge DWR – increase discharge to 21 kcfs
27. Ω \blacklozenge LIB – operate all available units (maintain minimum flow of 7 kcfs at night)
28. \blacklozenge JDA – increase operating pool range to a low of 260 ft.
29. \blacklozenge MCN – pull fish screens

Ω HGH & LIB may be initiated earlier than indicated on the list do to ramping requirements.

ψ Due to a fire at GCL 2nd powerhouse on 7/28/00, GCL is currently being base loaded and is not in a position at this time to respond as shown on the list above. This also impacts the operation of Banks Lake.

* Items 17-20 may be utilized for up to six hours at a time. Judi Johansen will coordinate with the General Strock if additional hours are required.

\blacklozenge Items 24–29 will required additional coordination between Judi Johansen and General Strock and Mr. McDonald before being implemented.