

List of FCRPS Operations
Arranged in an order to Reduce Biological Impacts
Which May Be Used During a NW or SW System Reliability
Event
Revised as of 8/24/00 TMT meeting

This list is a starting point and will be re-ordered through the TMT process prior to, and during, each event

1. Regional plea for energy conservation
2. Voluntary load curtailment of industrial users
3. Rescheduling of unit outages
4. Increase Willamette Projects' generation
5. Purchase all available energy
6. Maximize Treaty/Non Treaty water releases
7. JDA – increase operating range to 265 ft. to 262.5 ft.
8. GCL – draft to elevation 1280 feet
9. LWG – utilize full operating pool
10. ALF – operate at full power to elevation 2062 ft. mindful of ramp rates.
11. JDA – reduce daytime spill to zero
12. TDA – reduce spill to 30%
13. BON – reduce daytime spill to 50 kcfs
14. BON – operate outside of 1% operating efficiency
15. MCN – operate outside 1% operating efficiency at 50% overload (approx. 72 Mws)
16. TDA – reduce spill to 20%
17. JDA – reduce spill to 30% (nighttime)
18. *JDA – reduce spill to zero (nighttime)
19. *TDA – reduce spill to zero
20. *IHR – reduce spill to zero
21. *BON – reduce spill to zero
22. MCN - operate outside 1% operating efficiency at 100% overload (approx. 81 Mws)
23. Banks Lake – operate PGs / sag on Banks Lake to elevation 1565 ft.
24. ΩHGHI – operate all available units (bring up to 3 units until further notice)
25. ♦GCL – draft to elevation 1278 feet
26. ♦Snake River Projects – go to zero nighttime flow (lower Snake projects may go above MOP)
27. ♦DWR – increase discharge to 21 kcfs
28. Ω♦LIB – operate all available units (maintain minimum flow of 7 kcfs at night)
29. ♦JDA – increase operating pool range to a low of 260 ft.
30. ♦MCN – pull fish screens

Ω HGHI & LIB may be initiated earlier than indicated on the list do to ramping requirements.

* Items 17-20 may be utilized for up to six hours at a time. Judi Johansen will coordinate with the General Strock if additional hours are required.

Items 24–29 will required additional coordination between Judi Johansen and General Strock and Mr. McDonald before being implemented.

