

Posted July-20-2005

Invoked Only Upon Formal Emergency Declaration  
Notification to TMT as outlined in:  
2005 Water Management Plan – Appendix 1 Emergency Protocols

Group 1 (first taken)

Return all units to service by canceling or postponing scheduled outages  
Put into service all possible generators (e.g., Grand Coulee pump-generators, Hungry Horse, Willamette basin)  
Increase flows at specific projects to meet peak generation need without impacting spill programs;  
Buy energy/capacity at market prices  
Reduce or eliminate BPA non-firm contracts  
Exceed daily draft limits

Group 2 (second taken)

Operate projects outside of minimum operating pool ranges  
Adjust flows outside of planned targets or as preset by TMT  
Restrict intertie capacity reducing import or export  
Shed other non-BPA non-firm contracts  
Reduce firm loads  
Violate flood control or other first priority non-power requirements  
Buy energy/capacity at any price