

Spill priority list

Ice Harbor

Lower Monumental

Little Goose

Lower Granite

Bonneville - increase night time spill to 125% TDG, increase daytime to 120 kcfs

The Dalles - spill maximum q through bays 1-6 which equates to ~126kcfs spill

John Day - change spill block to 40% if it is a 30% block period

Wanapum

Priest Rapids

Rocky Reach

Wells

Rock Island

Chief Joseph – spill through deflector equipped bays only

Grand Coulee – spill up to 120% TDG if it reduces load substantially and reduces the need to spill at downstream projects in a significant way.

The Dalles

McNary – increase turbine loading to 14 kcfs per unit to keep TDG from exceeding 125%.

McNary

John Day

Bonneville