

FPP Change Form

Change Request Number: 10LWG003

Date: January 11, 2010

Proposed by: Laura Hamilton – NWD RCC– Water Quality

Reason for Change: The minimum generation information for low flow conditions needs to be updated to reflect actual operations.

Proposed Change: Section 4.1.2. At Lower Granite Dam, minimum generation requirements are 11.3 – 13.1 kcfs for turbine units 1 – 3 and 13.5 – 14.5 kcfs for turbine units 4-6. Actual attainable minimum generation levels may vary depending on project conditions.

Deleted: 2

Deleted: 2

Deleted: 3

Comments from others:

Record of Final Action:

FPOM approved this change form at the 1/13/10 meeting.