

Change Request Number: 11LMN001 Unit Priority

Date: 10/04/10

Proposed by: CRITFC

Location of Change- Table LMN-5

Table LMN-5. Turbine Unit Operating Priority for Lower Monumental Dam.

Season	River Flow	Spill Level	Unit Priority
Mar 1 – Nov 30	Less than 70 kcfs	Bulk Spill Gas Cap	2, 3 , 5*, 3 , 4, 6 then 1
	Over 70 kcfs	Bulk Spill Gas Cap	1**, 5*, 2, 3, 4, then 6
	Any River Flow	No Spill	2, 3, 4, 5, 6 then 1***
Dec 1 – Feb 28	Any River Flow	Any Spill Level, Including No spill	Any Order

*If U5 is OOS, run U4. **If U1 is OOS, run U2. ***If no spill is occurring, U1 may be operated at any priority level at the discretion of project personnel. **NOTE:** U1 has fixed-pitch blades and can operate only at about 130 megawatts.

Reason for Change: To better insure that in low flows we can meet 17 kcfs during the summer. Last year unit 2 was out and we had to use unit 5 some. Until 1 is no longer a fixed blade unit we would propose this modification. We went to this operation late this year to better hit the 17 kcfs.

Comments from others:

USFWS- support

Record of Final Action: this change form is similar to 11LMN002, except for the location of Unit 4. After discussions, this change form has been denied and LMN002 has been approved. 21 January 2011.