

FPP Change Form

Change Request Number: 11MCN004

Date: 3/4/2010

Proposed by: Bonneville Power Administration

Location of Change:

Proposed Change: 4.1 Turbine unit operation, table MCN-5 BPA proposes taking MCN turbine units 1-8 out of service from 1-15 August, and MCN turbine units 9-14 out of service from 15-31 August. There is flexibility to push the start of the second half to 22 August and go into September. Work in September may require some level of spill to pass inflow.

Reason for Change: MCN-JDA transmission line project - 2011. A new high voltage transmission line is being built between the John Day and McNary projects. To allow the line to be connected at the MCN substation outages must be taken to build the transmission towers and string new line over existing transmission lines servicing units at MCN dam. This outage has been sequenced to allow proper water temperature management at MCN dam. This change will only be in place for the 2011 season.

Comments from others: NOAA, CRITFC, USFWS, WDFW, IDFG and ODFW are ok with the plan as described.

Record of Final Action: approved at July 2010 FPOM.