

## **Fish Passage Plan (FPP) Change Request Form**

---

**Change Form # & Title:** 15IHR003 – Turbine Unit Operation  
**Date Submitted:** October 30, 2014  
**Project:** Ice Harbor Dam  
**Requester Name, Agency:** Ken Fone, Ice Harbor Dam  
**Final Action:** APPROVED – [January 22, 2015](#)

---

**FPP Section:** IHR 4.1.2.1 Turbine Unit Operation – Single Unit Operation.

**Justification for Change:** The incorrect unit operating priority in the text of the 2014 FPP is a remnant from prior years when unit 6 was run last in priority because of the need for governor repairs. The repairs were completed prior to 2014 and the operating priority in the table was changed back to the original desired unit priority, but the text was not changed due to an oversight.

**Proposed Change:**

**4.1.2.1.** If single unit operation is necessary and switching has not occurred in the yard, run unit 1, 2, ~~6, 5, 6~~. Running units 3 and 4 alone on the *Ice Harbor-Franklin No. 2 115kV* line can only occur if the powerhouse operator can accomplish the needed switching. If Unit 1 is out of service and switching has not occurred, then operate the following unit priority when operating more than one unit: 2, 3, ~~6, 4, 5, 6~~.

**Comments:**

1/16/15 NOAA memo: “Good catch. We may need to revisit this again soon as the new units are being installed and come into operation/testing mode in the next couple of years.”

**Record of Final Action:**

1/22/15 FPOM: APPROVED.