

FPP Change Request Form

Change Form # & Title: 15LWG003 – Spill Pattern Correction
Date Submitted: April 22, 2015
Project: LWG
Requester Name, Agency: Lisa Wright, COE RCC
Final Action: APPROVED – [May 14, 2015](#)

FPP Section: LWG Table LWG-8. Spring Spill Patterns with RSW.

Justification for Change: During a comparison of spill pattern tables in the FPP versus the patterns programmed into GDACS, an error was noted in Table LWG-8 for Spring Spill w/ RSW. The pattern with 18.5 total gate stops should have “Total Spill” of 33.2 kcfs (not 36.6). This was a typo that occurred when the table was created in 2003. However, the correct pattern is programmed into GDACS so this error has not had an impact on project operations.

Proposed Changes:

Table LWG-1. Lower Granite Dam Spring Spill Patterns with RSW.

Total Spill (kcfs)	Spring Spill Patterns with RSW (# Gate Stops/Spillbay)								Total Stops ^b (#)
	1 (RSW) ²	2	3	4	5	6	7	8	
31.3	3.5	2	2	2	2	2	2	2	17.5
36.6 33.2	3.5	2	2	3	2	2	2	2	18.5
35	3.5	2	2	3	3	2	2	2	19.5

Comments from others:

Record of Final Action:

APPROVED at FPOM meeting May 14, 2015