

FPP Change Request Form

Change Form # & Title: 16IHR002 – Table IHR-4 Unit Priority Order Clarification
Date Submitted: December 15, 2015
Project: Ice Harbor
Requester Name, Agency: Martin Law, Ken Fone, Ice Harbor Dam
Final Action: **APPROVED – January 28, 2016**

FPP Section: Ice Harbor, Section 4.1, Table IHR-4. Unit Priority Order.

Justification: This change in single unit operating priority with no line switching during the winter period will make the table more consistent with what is already occurring for multiple unit operation. This is more of a correction than a change in unit operating priority, as the inconsistency in the table may have been an oversight from years ago. Adult and juvenile fish passage is typically low during the winter maintenance period, which is why units can be operated in any order at that time.

Proposed Change:

Table IHR-1. Ice Harbor Dam Turbine Unit Operating Priority Order.

Season	Operation	Unit Priority Order
<u>Fish Passage Season</u> March 1 – November 30	Single-Unit Operation w/ NO <u>Line</u> Switching. <i>* <u>Line</u> Switching must occur prior to resuming normal priority order below.</i>	1,2,6,5
	Multiple-Unit Operation	1,3,6,4,2,5
		Unit 1 OOS and NO <u>Line</u> Switching: 2,3,6,4,5
<u>Winter Maintenance</u> December 1 – <u>end of February-28</u>	<u>Single-Unit Operation w/ NO Line Switching</u>	<u>Any order for units 1,2,5,6</u>
	Multiple-Unit Operation	Any Order

Comments:

Record of Final Action: APPROVED at FPP meeting 1/28/2016.