

SPILL PRIORITY LIST

Effective 24-MAR-2015 through 31-MAR-2015. ^a

Priority Order	Project	TDG Cap (%)	Example Spill Caps (kcfs)
LEVEL 1 (State TDG Standards ^a)			
1	LWG	110%	20
2	LGS	110%	18
3	LMN	110%	18
4	IHR	110%	25
5	MCN	110%	48
6	JDA	110%	20
7	TDA	110%	45
8	BON	110%	70
9	CHJ	110%	25
10	GCL ^b	110%	OT=0; DG=5
11	DWR	110%	35% of total outflow
LEVEL 2			
12	LWG	115%	30
13	LGS	115%	23
14	LMN	115%	23
15	IHR	115%	35
16	MCN	115%	80
17	JDA	115%	80
18	TDA	115%	60
19	BON	115%	100
20	CHJ	115%	61
21	GCL ^b	115%	OT=5; DG=15
LEVELS 3-7: same order as LEVEL 2			

^a From Sep 1-Mar 31, the Clean Water Act standard for total dissolved gas (TDG) is $\leq 110\%$ at all projects. From Apr 1-Aug 31, State TDG waivers are in effect at LWG, LGS, LMN, IHR, MCN, JDA, TDA and BON for TDG $\leq 120\%$ in the tailrace (OR, WA) and $\leq 115\%$ in next downstream forebay (WA), except BON which does not have a downstream forebay standard.

^b GCL spill is via outlet tubes (OT) or drumgates (DG). Transition to DG at forebay elevation 1267-1270 ft.